

1. Wiring Illustration

Only 3 part of wiring was necessary for wiring of ADL200/C and AWT100-WiFiHW


(1) Power Wiring of ADL200/C: Use PIN L, L', N, N' on ADL200 for current and voltage input (Noted, the wiring must be according to the actual live line current direction)

(2) Power Supply of AWT100-WiFiHW: Use PIN L, N on AWT100-POW for power supply (Noted: voltage level of power source must be with the range of 85~265Vac L-N)


(3) RS485 Communication Wiring between AWT100-WiFiHW and ADL200/C: PIN 21 of AWT100-WiFiHW connected to PIN 21 of first ADL200/C to PIN 21 of second ADL200/C and to PIN 21 of last ADL200/C. (RS485 Port A to Port A to Port A)

PIN 22 of AWT100-WiFiHW connected to PIN 22 of first ADL200/C to PIN 22 of second ADL200/C and to PIN 22 of last ADL200/C. (RS485 Port B to Port B to Port B)

***Extra Noted:** Before powering ADL200/C and AWT100-WiFiHW, make sure all the wiring was done and AWT100-WiFiHW was covered by stable WiFi signal (WiFi account and password same as preset.)




PIN Overview of ADL200/C



PIN Overview of AWT100-WiFiHW

1. Wiring Illustration

(1) Power Wiring of ADL200/C: Use PIN L, L', N, N' on ADL200 for current and voltage input, voltage input range 220~264Vac L-N, max current input 80A AC. (Noted,the wiring must be according to the actual live line current direction)




(1) Power Wiring of ADL200/C


1. Wiring Illustration

(2) Power Supply of AWT100-WiFiHW: Use PIN L, N on AWT100-POW for power supply (Noted: voltage level of power source must be with the range of 85~265Vac L-N)

(3) RS485 Communication Wiring between AWT100-WiFiHW and ADL200/C: PIN 21 of AWT100-WiFiHW connected to PIN 21 of first ADL200/C to PIN 21 of second ADL200/C and to PIN 21 of last ADL200/C. (So does the connection of PIN 22)



(2) Left Side - Power Supply Wiring of AWT100-WiFiHW (via AWT100-POW)



(3) RS485 Communication Wiring between ADL200/C&AWT100-WiFiHW

2. System Operation



After correctly installing, wiring and powering up the Acrel devices, there are 4 steps to bind these devices with Acrel System before formally using the system:

- (1) Step 1 - Download IoT EMS APP on your Mobile Phone;
- (2) Step 2 - Register and login your own account.
- (3) Step 3 - Create a new Project
- (4) Step 4 - Add devices to your new Project (Recommend to add by using APP)

Extra Noted: Acrel IoT EMS APP (for Mobile) and IoT EMS WEB (for PC) Share the same data and account, once add the devices using APP, we can check the data on IoT EMS WEB on PC.




(1) Download IoT EMS APP:

- Download Link (Android): <https://play.google.com/store/apps/details?id=com.acrel.iotems>
- Download (IOS): Search IoT EMS



(2) Register your own Account:

- Click on register
- Enter related information for registering account
- Login with your new account by entering "Account" and "Password" you just set



2. System Operation


After correctly installing, wiring and powering up the Acrel devices, there are 4 steps to bind these devices with Acrel System before formally using the system:

- (1) Step 1 - Download IoT EMS APP on your Mobile Phone;
- (2) Step 2 - Register and login your own account.
- (3) Step 3 - Create a new Project
- (4) Step 4 - Add devices to your new Project (Recommend to add by using APP)

Extra Noted: Acrel IoT EMS APP (for Mobile) and IoT EMS WEB (for PC) Share the same data and account, once add the devices using APP, we can check the data on IoT EMS WEB on PC.


(3) Create a new Project:

- "My" → "Project management"
- Click "+" icon on the right top
- Choose "Platform prepaid" and fill in other information marked by *



(2) Add Devices to Project:

- Enter "Add" interface
- Select "Project"
- Click "QR Code" scanning icon
- Scan the QR Code on AWT100-WiFiHW
- Downstream devices will be automatically recognized if connection success between AWT100-WiFiHW and ADL200/C



3. Acrel IoT Energy Monitoring System (Partail Introduction)

Acrel IoT Energy Monitoring System could be access in 2 different ways:

(1) Access through WEB on your computer.

Access port: <https://iot.acrel-eem.com/>

(2) Access through APP on your mobile phone


Download Link: <https://play.google.com/store/apps/details?id=com.acrel.iotems>

(1) WEB Accesss (Computer):

Access Port: <https://iot.acrel-eem.com/>

Account Name: (Enter yours)

Account Password: (Enter yours)





(2) APP Accesss (Mobile):

Download Link: <https://play.google.com/store/apps/details?id=com.acrel.iotems>

Account Name: (Enter yours)

Account Password: (Enter yours)




3. Acrel IoT Energy Monitoring System (Partail Introduction)


Main Function of WEB side System:

(1) Devices List (2) History Curve (3) Electricity Parameters Report (4) Energy Consumption Report (Daily, Monthly, Yearly) (5) User Report


(1) Devices List: Showing the overall devices connected to Acrel System and were bond to certain project. SN code, Online-Offline status, devices model and other necessary information will be shown here.



(2) History Curve: Showing the daily history data curve of all the data that could be collected and upload by energy meter or other basic metering devices.



(2) History Curve: By selecting the items of "data" and "electricity parameter", platform can show the history curve of different data and date.




3. Acrel IoT Energy Monitoring System (Partail Introduction)


Main Function of WEB side System:

(1) Devices List (2) History Curve (3) Electricity Parameters Report (4) Energy Consumption Report (Daily, Monthly, Yearly) (5) User Report


(5) User Report: A comprehensive user report including project overview, energy report, energy analysis and etc could be check on platform



(5) User Report: User report could be exported in "PDF" format into your PC for convenient check and storage.



(5) User Report: User report support template customization in buy-out service of Acrel IoT Energy Monitoring System.




3. Acrel IoT Energy Monitoring System (Partail Introduction)


Main Function of APP side System:

(1) Devices List (2) History Curve (3) Electricity Parameters Report (4) Energy Trend (5) Energy Consumption Report (Daily, Monthly, Yearly)


Noted: Since APP side and WEB side of Acrel IoT Energy Monitoring System share the same data, normally recommend our user to add the devices to their account using APP and check the data using WEB platform.




(1) Device List




(2) History Curve




(2) History Curve



(3) Parameter Report



(4) Energy Trend



(5) Energy Report