

Certificate of Conformity Electrical Equipment (Safety) Regulations 2016 (UK SI 2016 No. 1101)

Registration No.: AT78231SC201086

Report No.: 78231SC20108601

Applicant : Acrel Co., Ltd.
No.253, Yulv Road, Jiading District, Shanghai, China

Product : Single-Phase Electricity Meter

Model No. : DDS,DDS1352,DDS1352-C,DDSD,DDSD1352,DDSD1352-C,DDSD1352-FC,DDSY,DDSY1352,DDSY1352-Z,DDSY1352-NK,DDSY1352-RF,ADL,ADL10-E,ADL10-E/C,ADL100-E,ADL100-ET,ADL100-EY,ADL100-ET/FC,ADL100-ET/C,ADL100-EY/NK,ADL100-EY/Z,ADL100-EY/RF,ADL200,ADL200-F

Trade Mark : Acrel

Rating : Measuring Voltage input:AC0...230V;
Measuring Current input:AC0... 0A;0...60A;
Freq:50Hz

Test Standards : BS EN 61010-1:2010

The certificate of conformity is based on an evaluation of a sample of the abovementioned product. Technical report and documentation are at the applicant's disposal. This is to certify that the tested sample is in conformity with Electrical Equipment (Safety) Regulations 2016(UK SI 2016 No. 1101) by UK legislation. The certificate of conformity does not imply assessment of the production and does not permit the use of Lab's logo. The applicant is authorized to use this certificate in connection with UK Declaration of Conformity.

Nov. 09, 2022
Date



Certified by

Terry Tian
Manager



The UKCA Marking may only be used if all relevant and effective EU Directives are complied with



Shenzhen Anbotek Compliance Laboratory Limited

1/F, Building D, Sogood Science and Technology Park, Sanwei community, Hangcheng Street, Bao'an District, Shenzhen, Guangdong, China.518128

Tel: (86)755-26066440

Fax: (86)755-26014772

Http://www.anbotek.com

Email: service@anbotek.com

